

Project 603-14-303, Replace Air Handling Units (AHU), Phase IV  
Solicitation VA249-15-B-0365

**VENDOR QUESTIONS/GOVERNMENT RESPONSE**

**QUESTIONS:**

1. Please confirm who the fire alarm manufacturer and current vendor is in the VAMC?
2. Please clarify if sheet E6.03 should be E6.02?
3. Please clarify what keynote 3 is on sheet ED6.01?

**GOVERNMENT RESPONSE:**

1. FA manufacturer is Simplex-Grinnell. The current vendor would need to be answered by the VAMC.
2. Correct.
3. Feeder number 3 is (2) sets of 4-#3/0 + 1-#3G in 2-1/2" C.